FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15**

**1. TESTING OF FINE AGGREGATES :** **Date: 07-02-2015**

**Sub**: Testing of Fine Aggregates.
{Project*: Providing CC Roads in Yalumandamma Badavane in Ward No.10 (Doddabommasandra) Vidyaranyapura Sub Division}

**Ref.** : Letter No. Testing/BUB/2014-15, dated 04-02-2015

Sample supplied to lab by : Assistant Executive Engineer,
Vidyaranyapura Sub Division,
BBMP, Bangalore

Name of the Contractor/Agency*: Sri.Aswathnarayana Anjanappa, Contractor, Bangalore.

**TABLE - 1.1 : SIEVE ANALYSIS :**

| IS Sieve Size, mm | Percentage Passing | Specification as Per IS: 383-1970(Reaffirmed 2002) Percentage Passing | | | Remarks |
|---|---|---|---|---|---|
| | | Zone-I | Zone-II | Zone -III | |
| 04.75 | 96.90 | 90-100 | 90-100 | 90-100 | The Sample Conforms to Grading **Zone-II** |
| 02.36 | 80.20 | 60-95 | 75-100 | 85-100 | |
| 01.18 | 68.90 | 30-70 | 55-90 | 75-100 | |
| 600. mic | 44.00 | 15-34 | 35-59 | 60-79 | |
| 300.mic | 22.30 | 5-20 | 8-30 | 12-40 | |
| 150.mic | 3.10 | 0-10 | 0-10 | 0-10 | |

**TABLE 1.2 ;**

| Sl No | Test Conducted | Sample | Results | Requirements as Per IS. Specification IS :383-1970 (Reaffirmed 2002) |
|---|---|---|---|---|
| 1 | Silt Content | 001 | 1.42 % | Not more than 8% |
| 2. | Specific Gravity | ---- | 2.54 | ------- |

*As Furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

AE-10

Dr. MANJESH L
ME (Civil Engg ) Ph D MISTE MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15**

**1. TESTING OF COARSE AGGREGATES ( 40 mm):** **Date: 07-02-2015**

**Sub**: Testing of Coarse Aggregates.
{Project*: Providing CC Roads in Yalumandamma Badavane in Ward No.10 (Doddabommasandra) Vidyaranyapura Sub Division}

**Ref.** : Letter No. Testing/BUB/2014-15, dated 04-02-2015

Sample supplied to lab by : Assistant Executive Engineer,
Vidyaranyapura Sub Division,
BBMP, Bangalore

Name of the Contractor/Agency*: Sri.Aswathnarayana Anjanappa, Contractor, Bangalore.

**Table - 1.1 : SIEVE ANALYSIS** :

| IS Sieve Size, mm | Percentage passing | Requirements as per IS 383-1970 (Reaffirmed on 2002) % Passing | |
|---|---|---|---|
| | 40 mm Sample | *Single size* | *Graded* |
| 40mm | 97.00 | 85-100 | 95 – 100 |
| 20mm | 59.10 | 0 -20 | 30- 70 |
| 10mm | 29.30 | 0 -5 | 10- 35 |
| 4.75mm | Nil | ------ | 0 - 5 |

**TABLE 1 2 :**

| SL No | Test conducted | Sample No | Results | Requirements as per IS:383-1970 & Test Conforms to IS 2386( Part I to IV) – 1963 ( Reaffirmed on 2002) |
|---|---|---|---|---|
| 1. | Flakiness Index | As above | 16.10 % | Not to exceed 25 % |
| 2. | Crushing value | ----,,---- | 26.30 % | Not to exceed 45 % for concrete other than for wearing surfaces and 30% for concrete for wearing surfaces |

*As Furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

AE-10

Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

**BANGALORE UNIVERSITY**
**DEPARTMENT OF CIVIL ENGINEERING**

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15**

## 1. TEST REPORT ON CEMENT:

**Date: 13-02-2015**

**Sub:** Testing of 53 Grade Cement Sample (IS 12269-1987).
{Project*: Providing CC Roads in Yalumandamma Badavane in Ward No.10 (Doddabommasandra) Vidyaranyapura Sub Division}

**Ref.** : Letter No. Testing/BUB/2014-15, dated 04-02-2015

Sample supplied to lab by : Assistant Executive Engineer,
Vidyaranyapura Sub Division,
BBMP, Bangalore

Name of the Contractor/Agency*: Sri.Aswathnarayana Anjanappa, Contractor, Bangalore.

### PHYSICAL TESTS ON CEMENT

Brand* : Birla
Grade * : 53
Type * : OPC
Date : 05-02-2015 to 12-02-2015

| SL No | Name of Test | Results | Requirements as per |
|---|---|---|---|
| | | Cement Sample | IS 12269-1987 |
| 1 | Initial setting time | **145 min** | Shall not be less than 30 min |
| 2 | Final setting time | **250 min** | Shall not be more than 600 min |
| 3 | Fineness (by dry sieving on IS 90 micron sieve) | **2.60 %** | Not to exceed 10.0% |
| 4 | Soundness test(by Le-Chatelier's method) | **1.70 mm** | Shall not be more than 10 mm |
| 5 | Compressive strength<br>k) 3 days (average of three results)<br>l) 7 days ( average of three results) | **29.30 N/ Sq mm**<br><br>**40.80 N/Sq mm** | Shall not be less than 27 N/Sqmm<br><br>Shall not be less than 37N/Sqmm |

*As Furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

AE-10

13/02/2015
Dr. MANJESH .L
ME (Civil Engg ). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

# BANGALORE UNIVERSITY
## DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

**BUB/CTE/2014-15**

**DATE: 24-02-2015**

## 1. TEST REPORT ON CEMENT CONCRETE CUBES:

**Sub**: Testing of Concrete Cubes (07 days Compressive Strength)
{Project*: Providing CC Roads in Yalumandamma Badavane in Ward No.10 (Doddabommasandra) Vidyaranyapura Sub Division}

**Ref.** : Letter No. Testing/BUB/2014-15, dated 23-02-2015

Sample supplied to lab by : Assistant Executive Engineer,
Vidyaranyapura Sub Division,
BBMP, Bangalore

Name of the Contractor/Agency*: Sri.Aswathnarayana Anjanappa, Contractor, Bangalore.

### RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

### CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm

Grade of Concrete* : $M_{20}$

**TABLE 1.1 :**

| Sl No | Location/ Identification * | Date of Casting* | Date of Testing | Age in Days | C/S Area in $Mm^2$ | Maximum Load in K.N | Compressive Strength ($N/mm^2$) | Avg. Value |
|---|---|---|---|---|---|---|---|---|
| 1 | 001 | 16-02-15 | 23-02-15 | 07 | 22500 | 400 | 17.77 | **17.55** |
| | 002 | " | " | " | " | 390 | 17.33 | |
| | 003 | " | " | " | " | 395 | 17.55 | |

*As Furnished by Client.
The Results relate only to the items tested.



G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

AE-10

Dr. MANJESH .L
ME (Civil Engg ), Ph D MISTE MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com